

Appliance Testing Pass Certificate

Client Name	EUGENE PORTMAN	CERTIFICATE DATE: 20/09/2011
Address	LINGFIELD	
Location Name	LINGFIELD	
	LINGFIELD	

TEST RESULTS

Test Date	Appliance	Description	Class/ Voltage	Visual		Earth	Continuity	Insulation	Load	Leak.	Flash	
				Fuse	Cord							
20/09/1911	00000EU001	POWER UNIT FOR	2 230	P		S	S	>9.90 P	S	<0.05 P	0.47 P	S
20/09/1911	00000EU002	POWER UNIT FOR	2 230	P		S	S	>9.90 P	S	<0.05 P	0.60 P	S
20/09/1911	00000EU003	POWER UNIT	2 230	P		S	S	>9.90 P	S	<0.05 P	0.43 P	S
20/09/1911	00000EU004	POWER UNIT	2 230	P		S	S	>9.90 P	S	<0.05 P	0.43 P	S
20/09/1911	00000EU005	IEC LEAD	1 230	P		0.11 P	S	>9.90 P	S	<0.05 P	<0.30 P	S
20/09/1911	00000EU006	IEC LEAD	1 230	P		0.09 P	S	>9.90 P	S	<0.05 P	<0.30 P	S
20/09/1911	00000EU007	4 WAY EXTENSION LEAD	1 230	P		0.23 P	S	>9.90 P	S	<0.05 P	<0.30 P	S

(P-Pass, S-Skip, F-Fail)

CONTRACTOR DETAILS

Name	TGR Services		Engineer: Brian Davies BSc Hons BA DipCompOpen
Address	Red Roofs Crowhurst Road Crowhurst Lingfield Surrey RH7 6DG		
Signed			
	Date		20/9/2011

Asset Register

Report date: 20/09/2011

CLIENT: EUGENE PORTMAN

Location: LINGFIELD

Group: EXTENSION 4 WAY

Asset ID	Manufacturer/Description	Serial No.	Markings	Colour	Floor No.	Floor Name	Room ID
00000EU007	4 WAY EXTENSION LEAD						

Group: IEC MAINS LEAD

Asset ID	Manufacturer/Description	Serial No.	Markings	Colour	Floor No.	Floor Name	Room ID
00000EU005	IEC LEAD						
00000EU006	IEC LEAD						

Group: POWER UNIT

Asset ID	Manufacturer/Description	Serial No.	Markings	Colour	Floor No.	Floor Name	Room ID
00000EU001	YAMAHA POWER UNIT FOR KEYBOARD	LA20715T					
00000EU002	YAMAHA POWER UNIT FOR KEYBOARD	LA20714T					
00000EU003	BEHRINGER POWER UNIT	082DRÖL					
00000EU004	YAMAHA POWER UNIT	0852					

———— End of Report ————



Appliance Test History Report

Report date: 20/09/2011

CLIENT: EUGENE PORTMAN

Location: LINGFIELD

Asset ID	Manufacturer/Description	TestDate	Test reference	Overall	Visual	Earth 1	Earth 2	Ins. 1	Ins. 2	Flash1	Load	Leak	Fuse	Cord
00000EU001	YAMAHA POWER UNIT FOR KEYBOARD	20/09/1911	A2009I11459DAVIES	PASS	PASS			>9.90			<0.05	0.47		
00000EU002	YAMAHA POWER UNIT FOR KEYBOARD	20/09/1911	A2009I11459DAVIES	PASS	PASS			>9.90			<0.05	0.60		
00000EU003	BEHRINGER POWER UNIT	20/09/1911	A2009I11459DAVIES	PASS	PASS			>9.90			<0.05	0.43		
00000EU004	YAMAHA POWER UNIT	20/09/1911	A2009I11459DAVIES	PASS	PASS			>9.90			<0.05	0.43		
00000EU005	IEC LEAD	20/09/1911	A2009I11459DAVIES	PASS	PASS	0.11		>9.90			<0.05	<0.30		
00000EU006	IEC LEAD	20/09/1911	A2009I11459DAVIES	PASS	PASS	0.09		>9.90			<0.05	<0.30		
00000EU007	4 WAY EXTENSION LEAD	20/09/1911	A2009I11459DAVIES	PASS	PASS	0.23		>9.90			<0.05	<0.30		

———— End of Report ————

